

POOL INSPECTION CHECKLIST (NSW)

Indoor Pools

DOORS		
There is a latch on the door at least 1500mm above floor level on every door entering the pool area?		
	Yes	No
Doors open away from the pool area and are self-latching?		
	Yes	No
There are no pet doors or openings to the pool area greater than 100mm?		
	Yes	No
There are no wall openings greater than 100mm?		
	Yes	No
Is there a compliant CPR sign which can be easily read from a distance of 3 metres?		
	Yes	No
WINDOWS		
The windows can only open to a maximum of 100mm? OR		
	Yes	No
The windows are totally covered by bars or a metal screen? OR		
	Yes	No
The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor?		
	Yes	No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

My Pool Safety Inspector Pty Ltd - Brisbane | Gold Coast | Sydney www.mypsi.com.au | email@mypsi.com.au