



# POOL INSPECTION CHECKLIST (NSW)

Pools on a Property 2 Hectares or Larger

Built/Installed with Door & Window as Barrier Before 01/07/2010

## DOORS

There is a latch on the door at least 1500mm above floor level on every door entering the pool area?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
There are no pet doors or openings to the pool area greater than 100mm?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

## WINDOWS

The windows can only open to a maximum of 100mm? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The windows are totally covered by bars or a metal screen? <b>OR</b>	<input type="checkbox"/> Yes	<input type="checkbox"/> No
The height from the sill of the lowest opening panel of a window (to the pool area) is at least 1800mm from the floor?	<input type="checkbox"/> Yes	<input type="checkbox"/> No

The above checklist is to be used as a guide only. Please contact My Pool Safety Inspector for any specific advice you may require before your pool inspection.

[My Pool Safety Inspector Pty Ltd - Brisbane](#) | [Gold Coast](#) | [Sydney](#)

[www.mypsi.com.au](http://www.mypsi.com.au) | [email@myspi.com.au](mailto:email@myspi.com.au)